F	LECTRICAL LEGEND
LP-1,3 ◄◀ •	HOMERUN TO PNLBRD - ARROWS INDICATE NUMBER OF CIRCUITS. CROSS LINES INDICATE NUMBER OF CONDUCTORS OTHER THAN TWO (PROVIDE NUMBER OF WIRES REQUIRED TO ALLOW SWITCHING SHOWN - E10 SERIES LIGHTING DRAWINGS).
^ ^	CIRCUIT NUMBER(S)
	PANEL DESIGNATION
	WIRING CONCEALED IN WALL OR CEILING
	WIRING IN RACEWAY CONCEALED UNDER FLOOR
	2x4 RECESSED LIGHT FIXTURE
	1x4 SURFACE MOUNTED LIGHT FIXTURE
	2x2 RECESSED LIGHT FIXTURE
0	SURFACE MOUNTED ROUND LIGHT FIXTURE
©	PENDANT LIGHT FIXTURE
0	RECESSED DOWNLIGHT FIXTURE
수	WALL SCONCE LIGHT FIXTURE
\$	SINGLE POLE SWITCH - MOUNTED C/L UP 48" UNLESS NOTED OTHERWISE
\$3	THREE WAY SWITCH - MOUNTED C/L UP 48" UNLESS NOTED OTHERWISE - SUBLETTER INDICATES SWITCH CONTROL
©	OCCUPANCY SENSOR
\$ _D	DIMMER SWITCH - MOUNTED C/L UP 48" UNLESS NOTED OTHERWISE - SUBLETTER INDICATES SWITCH CONTROL
\$ _M	MOTOR RATED SWITCH
S WP	SERVICE SWITCH - TAYMAC PTC100GY
Ħ	DUPLEX CONVENIENCE RECEPTACLE - MOUNTED C/L UP 18" UNLESS NOTED OTHERWISE
⊭	DOUBLE DUPLEX CONVENIENCE RECEPTACLE - MOUNTED C/L UP 18" UNLESS NOTED OTHERWISE
⊨	GFCI DUPLEX CONVENIENCE RECEPTACLE - MOUNTED C/L UP 18" UNLESS NOTED OTHERWISE
Ю	SPECIALTY RECEPTACLE
H	DATA OUTLET - JUNCTION BOX WITH ONE 3/4" CONDUIT TO ABOVE AN ACCESSIBLE CEILING
₩ AP	WIRELESS ACCESS POINT
\bowtie^{w}	WALL PHONE OUTLET
K	VOICE OUTLET - JUNCTION BOX WITH ONE 3/4" CONDUIT TO ABOVE AN ACCESSIBLE CEILING
₩	VOICE/DATA OUTLET - JUNCTION BOX WITH ONE 3/4" CONDUIT TO ABOVE AN ACCESSIBLE CEILING
•	PUSH BUTTON
J	JUNCTION BOX
E	FLOOR BOX
P	FURNITURE FEED FLOOR BOX - POWER - HUBBELL LO-CON SC3098A FRAME WITH SS309SF 3/4" TRADE SIZE PLATE (SS309BF BLANK PLATE FOR OPPOSITE SIDE IF REQUIRED)
	FURNITURE FEED FLOOR BOX - DATA - HUBBELL LO-CON SC3098A FRAME WITH SS309SF 3/4" TRADE SIZE PLATE (SS309BF BLANK PLATE FOR OPPOSITE SIDE IF REQUIRED)
PP	POWER POLE
₽	DISCONNECT SWITCH
ď	FUSED DISCONNECT SWITCH
\bigcirc	ELECTRICAL MOTOR
TZ/ZI	EXISTING PANELBOARD
_	PANELBOARD
	CCTV CAMERA
AIM	ADDRESSIBLE INPUT (MONITOR) MODULE
FACP	FIRE ALARM CONTROL PANEL
F	FIRE ALARM MANUAL PULL STATION - MOUNTED C/L UP 48"
	FIRE ALARM HORN/LIGHT UNIT - CANDLE POWER (CD) PER NFPA 72 AND AS NOTED - 15/75 WHERE NOT OTHERWISE INDICATED ON PLANS - MOUNTED BOTTOM OF STROBE UP 80" ON WALL
図	FIRE ALARM STROBE LIGHT UNIT - CANDLE POWER (CD) PER NFPA 72 AND AS NOTED - 15/75 WHERE NOT OTHERWISE INDICATED ON PLANS - MOUNTED BOTTOM OF STROBE UP 80" ON WALL
CR	FOB ACCESS CARD READER
DΗ	FIRE ALARM MAGNETIC DOOR HOLDER
③	FIRE ALARM SMOKE DETECTOR - CEILING MOUNTED
^	

EXIT SIGN WITH ARROWS AS INDICATED OR HATCH INDICATES FACE - CEILING MOUNTED - FED FROM LOCAL NORMAL

EXIT SIGN WITH ARROWS AS INDICATED OR HATCH INDICATES FACE - WALL MOUNTED DIRECTLY ABOVE DOOR - FED

WALL MOUNTED EMERGENCY LIGHTING BATTERY UNIT - FED FROM LOCAL NORMAL LIGHTING CIRCUIT SERVING SPACE

CEILING MOUNTED EMERGENCY LIGHTING BATTERY UNIT - FED FROM LOCAL NORMAL LIGHTING CIRCUIT SERVING SPACE

LIGHTING FIXTURE SCHEDULE ALL FIXTURES SHALL BE FURNISHED COMPLETE WITH ALL HARDWARE LAMPS, HANGERS, FITTINGS, ETC. FOR A COMPLETE AND PROPER INSTALLATION									
TYPE	MANUFACTURER	CATALOG NO.	МТО	VOLT	LAMPS			DEMARKO/DALLACT INFORMATION	
			MTG.		NO.	WATT	TYPE	REMARKS/BALLAST INFORMATION	
	LED RECESSED 2X4 TROFFER		•	•			•	•	
Α	METALUX	2GRFA-LD1-38-A19/156-UNV-L830-CD1-U	R	UNV	LED	38	LED		
	LED RECESSED 2X4 TROFFER	WITH TRIPLE GASKETING	•	•			•		
AG	METALUX	2GRFA-LD1-38-A19/156-UNV-L830-CD1-G3-U-DF-24-W	R	UNV	LED	38	LED	PROVIDE WITH 2'X4' DRYWALL FRAME KIT.	
	LED SURFACE MOUNTED 1X4	FIXTURE		1					
В	RLE INDUSTRIES	7200LED-1X4-V2-4.7-N-UNV-30K-A19/156-DM	s	UNV	LED	40	LED	PROVIDE WITH 0-10V DIMMING DRIVER	
	LED RECESSED DOWNLIGHT		<u> </u>						
С	PORTFOLIO	LD6A10D010TE-ERM6A10830-6LM1LIWF-HB26	R	UNV	LED	14	LED		
	LED RESTROOM VANITY FIXTU	JRE	<u> </u>	<u> </u>			l		
D	TERON LIGHITNG	VCY24-L18.0-100/277-SM-30K	— w	120	LED	16	LED		
	LED WALL MOUNTED FIXTURE	LED WALL MOUNTED FIXTURE							
F	XELEUM	XALF04-M30KUN	— w	UNV	LED	32	LED		
	LED LINER VAPORTITE								
G	METALUX	4VT2-LED4-4-DR-UNV-L835-CD1-WL-TEH	s	UNV	LED	38	LED		



HARRIMAN

AUBURN PORTLAND MANCHESTER


RENOVATIONS FOR **ALERE**

SCARBOROUGH, ME

Harriman Project No. Key Plan



Issues and Revisions Mark Date Description -- 02-04-16 CONSTRUCTION DOCUMENTS



Drawing Scales PA / PE: JWT © 2016 Harriman Associates Drawn By: BSO

ELECTRICAL LEGEND, **NOTES AND** SCHEDULES

E00.1

A	METALOX	2GRFA-LD1-36-A19/136-UNV-L630-CD1-U	R	UNV	LED	38	LED		
	LED RECESSED 2X4 TROFFER WITH TRIPLE GASKETING								
AG	METALUX	2GRFA-LD1-38-A19/156-UNV-L830-CD1-G3-U-DF-24-W	R	UNV	LED	38	LED	PROVIDE WITH 2'X4' DRYWALL FRAME KIT.	
				UNV	LED				
	LED SURFACE MOUNTED 1X4 FIXTURE								
В	RLE INDUSTRIES	7200LED-1X4-V2-4.7-N-UNV-30K-A19/156-DM	S	UNV	LED	40	LED	PROVIDE WITH 0-10V DIMMING DRIVER	
			<u> </u>	UNV	LED	40			
	LED RECESSED DOWNLIGHT								
С	PORTFOLIO	LD6A10D010TE-ERM6A10830-6LM1LIWF-HB26	R	UNV	LED	14	LED		
			IX	ONV	LLD	14			
D	LED RESTROOM VANITY FIXTURE								
	TERON LIGHITNG	VCY24-L18.0-100/277-SM-30K	W	120	LED	16	LED		
			VV	120	LLD	10			
	LED WALL MOUNTED FIXTURE								
F	XELEUM	XALF04-M30KUN	l w	UNV	LED	32	LED		
			<u> </u>	UNV	LLD	JZ			
	LED LINER VAPORTITE								
G	METALUX	4VT2-LED4-4-DR-UNV-L835-CD1-WL-TEH	s	UNV	LED	38	LED		
			3	OIV		30			

Þ⊠Þ

FIRE ALARM MASTER BOX

LIGHTING CIRCUIT SERVING SPACE

EMERGENCY LIGHTING REMOTE HEAD

EXISTING ITEMS SHOWN DASHED

WEATHER PROOF

FROM LOCAL NORMAL LIGHTING CIRCUIT SERVING SPACE